


2018 Lorain County Fair Fire Safety Inspection Guidelines

To ensure all vendors are treated fairly, each vendor, exhibitor, etc., will be required to abide by the following regulations. All tents, trailers, exhibits, and barns will be inspected on Monday between 11:00 am – 4:00 pm. If violations are found, they will require immediate correction. If violations are not corrected by noon on Tuesday, the exhibit will be closed until compliance is met. The following regulations are those that are most often a concern for exhibitors at the fair. For further explanation, please go to www.wellingtonfire.com/index.asp?pgid=175 for the complete code regulations.


ALL tents must have a **2A:10BC** fire extinguisher that is properly tagged. The important component is the **2A** rating. It is also important that an **inspection tag**, as shown in the picture below, is attached to the extinguisher.



2A rating

ALL cooking vendors must have a **40BC** fire extinguisher. A **40BC** extinguisher is different from an ABC extinguisher in that the **40BC** extinguisher is specifically designed for cooking type fires. Again, any cooking operation is **REQUIRED** to have a **40BC** fire extinguisher. Deep fat frying involving vegetable oils, animal fats, or solid fuel cooking, whether or not it's under a hood or suppression system, are required to have a Class K extinguisher present.

Any vendor/exhibitor that is using an **extension cord** must ensure that the cord is no smaller than **16/3**. Also, inspectors will check that the ground plug is not missing.



Ground Plug

Any vendor/exhibitor that is using a **multi-plug adapter** not provided by the Lorain County Fair Board must ensure that the adapter has a thermal protection/overload switch for protection.

Any vendor/exhibitor that is using a **clamp-style light** must also secure the light with a wire tie, wire, or some other acceptable manner to ensure that the light cannot fall.

